

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
P.O. - Kenduadihi, P.S. - Bankura, Pin - 722102**

Memo No : IND/WB/FES/20182019/36442

DATE: 08/12/2018

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**BANKURA UNNAYANI INSTITUTE OF ENGINEERING
POHABAGAN, BHAGABANDH, BANKURA
Bankura F.S., Bankura P.S.,
Bankura - 722146 .**

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational in favour of "BANKURA UNNAYANI INSTITUTE OF ENGINEERING" at the premises no.- POHABAGAN, BHAGABANDH, P.S & Dist. BANKURA, Pin - 722146.

This is in reference to your Application No. IND/WB/FES/20182019/36442,dated 08/12/2018, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational in favour of "BANKURA UNNAYANI INSTITUTE OF ENGINEERING" at the premises no.- POHABAGAN, BHAGABANDH, P.S & Dist. BANKURA, Pin - 722146..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1.Fire License shall have to be obtained for storing and processing with highly combustible articles.

2. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way. Basement shall not be used other than Car parking.
3. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
4. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
5. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
6. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
8. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
9. First aid firefighting system shall be provided as per I.S specification.
10. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
11. Each year a certificate is to be obtained from West Bengal Fire & Emergency Services, certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services